THIS DOCUMENT IS TRUE AND CORRECT AT TIME OF PUBLICATION. CONTINUED PRODUCT IMPROVEMENTS MAKE SPECIFICATIONS AND MEASUREMENTS SUBJECT TO CHANGE WITHOUT NOTICE.



NOTES:

1. USE 0.038 TIP DIA. INTERNAL/EXTERNAL (CONVERTIBLE) RETAINING RING PLIERS (NOT SUPPLIED) TO REMOVE HOUSING (NOZZLE)
2. IF NEEDED USE 2 HEX KEYS (NOT SUPPLIED) FOR SCREW REMOVAL. SEE OPERATION AND MAINTENANCE MANUAL FOR HEAD DISASSEMBLY AND REASSEMBLY INSTRUCTIONS.
3. THE HANDLE/STEM REPAIR KIT FOR THIS MODEL IS: 5830HST.
4. THE VALVE REPAIR KIT FOR THIS MODEL IS: IS: 5800VRKT.

DWG. NO. 15213A00

Haws corporation
INFO FAX : 1-888-FAX-HAWS (1-888-329-4297)
1455 Kleppe Ln, Sparks NV, 89431
Phone: 775-359-4712 Fax: 775-359-7424
Haws Ag Bachweg 3 CH-3401 Burgdorf Switzerland
Haws Mfg Pte Ltd 74 Sungei Kadut Loop Singapore 729531
e-mail: Haws@hawsco.com website: www.hawsco.com

ECR NO.	REVISED PER	BY:	MODEL(S): ENVIROGUARD® DRINKING FAUCET	PART NUMBER:
3810	ECN: 3889	HM	5054EG	0002081885.D
DRAWN: MD	DATE: 12/09/05	CHK'D.:	INFO FAX DOC #: 2505434	DRAWING NUMBER: 15213A00 REV. 3
APPROVED:	DATE:		SCALE: 1:3 DRAWING TYPE: INSTALLATION/FAXBACK	SIZE: A SHT. 1 OF 1

©2006 Haws Corporation - All Rights Reserved HAWS® and other trademarks used in these materials are the exclusive property of Haws Corporation.