



- NOTES:
1. DIMENSIONS MAY VARY BY ± 1/2 INCH (13mm).
  2. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY SHOWER EQUIPMENT:
    - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
    - SHOWER SHALL BE POSITIONED SO THAT SHOWER HEAD IS NOT LESS THAN 208.3 CM (82 IN.) NOR MORE THAN 243.8 CM (96 IN.) FROM SURFACE ON WHICH USER STANDS.
    - SHOWER SPRAY PATTERN SHALL HAVE A MINIMUM DIAMETER OF 50.8 CM (20 IN.) AT 152.4 CM (60 IN.) ABOVE SURFACE ON WHICH USER STANDS, AND CENTER OF SPRAY PATTERN SHALL BE LOCATED AT LEAST 40.6 CM (16 IN.) FROM ANY OBSTRUCTION.
  3. FOLLOWING THESE DIMENSIONS WILL AUTOMATICALLY PROVIDE ADHERENCE TO ANSI REQUIREMENTS STATED ABOVE.
  4. 1" IPS GALVANIZED PIPE NOT SUPPLIED.
  5. DO NOT USE REGULAR PIPE SEALANT. IF NECESSARY USE DOW CORNING 832 SEALANT PLACING 5 SMALL BEADS ON THE MALE THREADS, JUST ABOVE THE FIRST THREAD.

<b>Haws Corporation</b>		1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWSCO.COM WEBSITE: WWW.HAWSCO.COM	
EQN NO: 1 DRAWN: ECKM, 4/26/07 DATE: 05/23/07 TRF: [ ] APPROVED: [ ] SCALE: AS SHOWN DRAWING TYPE: INSTALLATION/DRAWBACK	IP: [ ] CHECK: [ ] DATE: [ ] INFO FAX DOC #: 2811137	MODEL(S): WALL MOUNTED FREEZE RESISTANT 8111FP DRENCH SHOWER 0002080111.D DRAWING NUMBER: 09438A00 SHEET: 1 OF 1	REV: [ ] 112