





**MOUNTING DETAIL  
BACK VIEW**




**DETAIL A**

**NOTES:**

- 1 PRODUCT BUNDLES AVAILABLE:  
MODEL 1109FRB (QTY. 1 EACH 1109FR, 6521FR & 6700)  
MODEL 1109FRP (QTY. 1 EACH 1109FR, BP3, 1920FR\*, BP15\* & 6469\* (NOT SHOWN), QTY. 2 EACH 6521FR & 6700). SEE 6521FR INSTALLATION INSTRUCTIONS FOR CONNECTION DETAILS.
- 2 VALVE ASSEMBLY MUST BE INSTALLED IN A WARM AREA. PROVISIONS SHOULD BE MADE TO ALLOW ACCESS TO ACCESS PANEL.

- 3 MAXIMUM ADJUSTABLE RANGE IS 15° FROM PARALLEL TO BACK OF WALL.
4. HOLD ROUGH-IN DIMENSIONS  $\pm 1/4"$  (6.4mm).
- 5.\* WHEN INSTALLING THIS UNIT LOCAL, STATE OR FEDERAL CODES SHOULD BE ADHERED TO. FOR INSTALLATION HEIGHTS OTHER THAN SHOWN, DIMENSIONS MARKED (\*) MUST BE ADJUSTED ACCORDINGLY.

				1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM			
ECN NO.	REVISED PER	BY:	MODEL(S)	1109FR			
DRAWN:	DATE:	CHK'D:					
F.V.	06-01-98	KM					
APPROVED:	DATE:						
FV	10/17/24						
SCALE: 1:16				DRAWING TYPE: INSTALLATION			
				SIZE: A			
				SHEET 1 OF 1			
				PART NUMBER 0002076626.D			
				REVISION 17			