



NOTES:

1. WHEN INSTALLING THIS UNIT, LOCAL, STATE, OR FEDERAL CODES SHOULD BE ADHERED TO FOR INSTALLATION DIMENSIONS (LOCATIONS), WASTE AND SUPPLY REQUIREMENTS OTHER THAN SHOWN.
2. TO COMPLY WITH ANSI Z358.1-2014 FOR EMERGENCY SHOWER EQUIPMENT:
  - SHOWER SHALL BE POSITIONED SUCH THAT SHOWER HEAD IS NO LESS THAN 82" (2083mm) AND NO GREATER THAN 96" (2438mm) FROM SURFACE ON WHICH USER STANDS.
  - SHOWER SPRAY PATTERN SHALL HAVE A MINIMUM DIAMETER OF 20" (508mm) AT 60" (1524mm) ABOVE SURFACE ON WHICH USER STANDS, AND CENTER OF SPRAY PATTERN SHALL BE LOCATED NO LESS THAN 16" (406mm) FROM NEAREST OBSTRUCTION.
3. DIMENSIONS MAY VARY BY  $\pm 1/2"$  (13 mm).

		<b>Haws®</b>		1455 KLEPPE LANE	
				SPARKS, NEVADA 89431	
ECN NO. REVISED PER BY:		MODEL(S)		PART NUMBER	
DRAWN: TRF		DATE: 5/15/91		8133H SHOWER	
APPROVED: FV		DATE: 02/16/18		0002080135.D	
		SCALE: NA		REVISION	
		DRAWING TYPE: INSTALLATION		13	
		SIZE: A		SHEET 1 OF 1	
				WEBSITE: WWW.HAWSCO.COM	