### **ANSI/ISEA Z358.1-2014 SAFETY EQUIPMENT CHECKLIST**

### **WEEKLY** MINIMUM PERFORMANCE REQUIREMENTS

- 1 Emergency equipment shall be activated weekly.
- 2 Activation shall ensure flow of water to the head(s) of the device.
- 3 Duration of the activation shall be sufficient to ensure all stagnant water is flushed from the unit itself and all sections of piping that do not form part of a constant circulation system. (also known as "dead leg" portions)
- 4 Self-Contained/Portable Equipment shall be visually checked to determine if flushing fluid needs to be changed.

### **ANNUAL MINIMUM PERFORMANCE REQUIREMENTS** All shower units shall be inspected **annually** to assure conformance with ANSI/ISEA Z358.1-2014. Recommended Testing Flow Pressure is 30 psi (+ .5 psi – .0 psi). LOCATION Safety station shall be accessible Showerhead must be 82 to 96 inches within 10 seconds of hazard, (208.3 cm - 243.8 cm) above the approximately 55 ft./16.8 m. surface floor of user. (Sec. 4.1.3, 7.1) (Sec. 4.5.2, 5.4.2, 6.4.2, 7.4.2) Shower must deliver minimum of 20 gallons Safety station shall be located on (75.7L) for 15 minutes and provide the same level as the hazard and a column of water 20 inches (50.8 cm) the path of travel shall be free of wide at 60 inches (152.4 cm) above the obstructions. (Sec. 4.5.2, 5.4.2, surface floor of user and be 16" from 6.4.2, 7.4.2) any obstruction. (Sec. 4.1.2, 4.1.4, 7.1) Emergency equipment location Shall be designed so that the flushing flow remains on without the use of the operator's shall be well lit and identified with a highly visible sign. hands. The valve shall be simple to operate (Sec. 4.5.3, 5.4.3, 6.4.3, 7.4.3) and go from "off" to "on" in one second or less and actuator can not be more than All employees subject to exposure 69 inches (173.3 cm) from the surface floor to hazardous material should be of user. (Sec. 4.2, 7.2) instructed in the location and **EYEWASH / EYE/FACE WASH** proper use of emergency Must provide a means of controlled flow equipment. (Sec. 4.6.4, 5.5.4, 6.5.4, 7.5.4) to both eyes simultaneously at a velocity low enough to be non-injurious. Where the possibility of freezing (Sec. 5.1.1, 6.1.1, 7.1) conditions exists, the unit shall be protected from freezing or Eye/face wash equipment must deliver minimum of 3 gallons (11.4 L) per minute freeze-protected equipment shall of water for 15 minutes. (Sec. 6.1.6, 7.1) be installed. (Sec. 4.5.5, 5.4.5, 6.4.5, 7.4.4) Eyewash only must deliver minimum of .4 gallon (1.5 L) per minute of water for **COMBINATION UNIT** 15 minutes. (Sec 5.1.6, 7.1) Combination unit components shall be capable of operating Outlets shall be protected from airborne contaminants. (Sec. 5.1.3, 6.1.3, 7.1) simultaneously and shall be positioned so that components The flushing fluid of an eyewash - eye/ may be used simultaneously by the same user. (Sec. 7.3, 7.4.4) face wash shall cover the areas between the interior and exterior lines of a gauge **DRENCH HOSE** at some point less than 8 inches (20.3 cm) Drench hose must deliver a above the eyewash nozzle. controlled flow of flushing fluid (Sec. 5.1.8, 6.1.8, 7.1) at a velocity low enough to be non-injurious. (Sec. 8.2.1) Flushing fluid flow pattern should be 33 to 53 inches (83.8 cm - 134.6 cm) A arench nose can only be from the surface floor of user and minimum considered an eyewash - eye/ of 6 inches (15.3 cm) from any obstruction. face wash if it meets performance (Sec. 5.4.4, 6.4.4, 7.1) requirements in Sec. 5 and/or 6. (See Eyewash / Eye/Face Wash Shall be designed so that the flushing flow Model 8300-8309 remains on without the use of the operator's section) hands. The valve shall be simple to operate **TEMPERATURE** and go from "off" to "on" in one second or less. Deliver tepid flushing fluid. (Sec. 5.2, 6.2, 7.2) Temperature range – above 60° F (16 $^{\circ}$ C) and below 100 $^{\circ}$ F (38 $^{\circ}$ C). (Sec. 4.5.6, 5.4.6, 6.4.6, 7.4.5)

For a FREE ANSI/ISEA Z358.1-2014 Survey at your site, call 888.640.4297 • www.hawsco.com/services

Please note that Haws Corporation® manufactures and sells emergency equipment and is not licensed or accredited as a health and/or safety specialist. Accordingly, you may wish to enlist the services of an accredited expert concerning compliance to the ANSI/ISEA 7358.1-2014 emergency equipment standards. Surveys conducted by a representative of the Haws Corporation are not intended as accredited safety review and are not to be relied upon for that purpose.

# www.hawsco.com/services



# ANSI/ISEA Z358.1-2014 SAFETY EQUIPMENT MINIMUM PERFORMANCE CHECKLIST

### **US/Canada**

Haws HQ • www.hawsco.com • +1.888.640.4297

### **Latin America**

Haws LATAM • www.hawsco.com.br • +55.11.4813.9977

### **Asia Pacific**

Haws APAC • www.haws.sg • +65.6367.0359

### **Europe/Middle East/Africa**

Haws EMEA • www.haws.ch • +41 (0) 34.420.6000



1455 KLEPPE LANE · SPARKS, NV 89431

www.hawsco.com • 1.888.640.4297 • +1.775.359.4712 • fax: 1.775.359.7424 • email: info@hawsco.com ©2024 Haws • All Rights Reserved • REV 0324

# **ANSI/ISEA Z358.1 SITE SURVEY PROGRAM**

ANSI/ISEA Z358.1 Compliant

88% of Units Are Not

COMPLIANT: 12%

**OTHER, 10%** NON-COMPLIANT:

action to ensure ANSI/ISEA Z358.1-2014 compliance and proper functionality and eye/face was survey. Know your current state and Protect your investment by taking advantage of our one-day free shower Shower and Eye/Face Wash ANSI/ISEA Z358.1 Site Survey Program can help. Want to reach ANSI/ISEA Z358.1-2014 compliance? Haws® Emergency in any emergency. ake necessary

visit https://www.hawsco.com/support/survey/ For more information and to schedule a site survey,

(Some Restrictions Apply)

NON-COMPLIANT: PERFORMANCE RELATED, 78%

1000+ Units Surveyed



### **ANSI ESEW Testing** Kit model 9011

5-gallon bucket with lid and marked 2-gallon testing line, shower sock with and ANSI/ISEA Z358.1-2014 checklist with testing instructions. 3-piece pole, eyewash gauge, tape measure, testing tag, thermometer, The ANSI Emergency Shower and Eyewash (ESEW) testing kit includes a

## **AXION Advantage® Kits**

optimal victim comfort solution while maintaining ANSI/ISEA Z358.1-2014 compliance\*. MSR design and technology for upgrading existing emergency equipment, providing the The AXION Advantage systems offer safety professionals the medically superior AXION®



### model AX13

system with green ABS Eye/face wash upgrade head plastic eye/face wash



Eye/face wash upgrade eye/face wash head system with stainless steel



### model AX14

upgrade system with green ABS plastic eye/face wash Shower and eye/face wash head and showerhead



### model **AX14S**

with stainless steel eye/ wash upgrade system Shower and eye/face face wash head and

\*when installed properly